

PRODUCT RECALL NOTICE

2460J - FLUKE SM100 SOCKET TESTER

Screwfix has been made aware that in some circumstances a very small number of products have shown that, in certain test conditions, there is a potential that metallic parts of the socket being tested could become live, posing a risk of electric shock to the user.

The product affected is:

| Code | Product Description | Barcode | Model Number |
|-------|---------------------------|--------------|--------------|
| 2460J | FLUKE SOCKET TESTER SM100 | 095969284615 | SM100 |

These products were offered for sale between 08/03/2016 and 23/01/2018.



If you have purchased this product, please stop using it immediately.

To receive a refund, please return the item to your local **Screwfix Trade Counter** where you will be given a refund to the full value of your purchase. If you require further information, please email recall@screwfix.com, call 03330 112 112 or visit our website for more information:

www.screwfix.com/recall

If you have purchased the Fluke SM100 Socket Tester for customers in the course of your own business, please contact them immediately, advise them to stop using the Socket Tester and make arrangements for it to be returned, as above

Thank you in advance for your co-operation in this matter and we apologise for any inconvenience caused.